

**Analytical Results**

**TASK NO: 200925074**

**Report To:** Justin Watanabe  
**Company:** Clear Creek School District  
320 Chicago Creek Rd  
Idaho Springs CO 80452

**Bill To:** Justin Watanabe  
**Company:** Clear Creek School District  
320 Chicago Creek Rd  
Idaho Springs CO 80452

<b>Task No.:</b> 200925074	<b>Date Received:</b> 9/25/20
<b>Client PO:</b>	<b>Date Reported:</b> 10/2/20
<b>Client Project:</b> Carlson ES	<b>Matrix:</b> Water - Drinking

**Customer Sample ID** Café  
**Sample Date/Time:** 9/22/20 6:28 AM  
**Lab Number:** 200925074-01

Test	Result	Method	ML	Date Analyzed	Analyzed By	MCL
<i>Total</i>						
Lead	< 0.0001 mg/L	EPA 200.8	0.0001 mg/L	9/28/20	IPC	0.015

**Abbreviations/ References:**

ML = Minimum Level = LRL = RL  
MCL = Maximum Contaminant Level per The EPA  
mg/L = Milligrams Per Liter or PPM  
ug/L = Micrograms Per Liter or PPB  
mpn/100 mls = Most Probable Number Index/ 100 mls  
Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

**Analytical Results**

**TASK NO: 200925074**

**Report To:** Justin Watanabe  
**Company:** Clear Creek School District  
320 Chicago Creek Rd  
Idaho Springs CO 80452

**Bill To:** Justin Watanabe  
**Company:** Clear Creek School District  
320 Chicago Creek Rd  
Idaho Springs CO 80452

<b>Task No.:</b> 200925074	<b>Date Received:</b> 9/25/20
<b>Client PO:</b>	<b>Date Reported:</b> 10/2/20
<b>Client Project:</b> Carlson ES	<b>Matrix:</b> Water - Drinking

**Customer Sample ID** RM 155  
**Sample Date/Time:** 9/22/20 6:30 AM  
**Lab Number:** 200925074-02

Test	Result	Method	ML	Date Analyzed	Analyzed By	MCL
<i>Total</i>						
Lead	0.0007 mg/L	EPA 200.8	0.0001 mg/L	9/28/20	IPC	0.015

**Abbreviations/ References:**  
 ML = Minimum Level = LRL = RL  
 MCL = Maximum Contaminant Level per The EPA  
 mg/L = Milligrams Per Liter or PPM  
 ug/L = Micrograms Per Liter or PPB  
 mpn/100 mls = Most Probable Number Index/ 100 mls  
 Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

**Analytical Results**

**TASK NO: 200925074**

**Report To:** Justin Watanabe  
**Company:** Clear Creek School District  
320 Chicago Creek Rd  
Idaho Springs CO 80452

**Bill To:** Justin Watanabe  
**Company:** Clear Creek School District  
320 Chicago Creek Rd  
Idaho Springs CO 80452

<b>Task No.:</b> 200925074	<b>Date Received:</b> 9/25/20
<b>Client PO:</b>	<b>Date Reported:</b> 10/2/20
<b>Client Project:</b> Carlson ES	<b>Matrix:</b> Water - Drinking

**Customer Sample ID** Rm 159  
**Sample Date/Time:** 9/22/20 6:32 AM  
**Lab Number:** 200925074-03

Test	Result	Method	ML	Date Analyzed	Analyzed By	MCL
<i>Total</i>						
Lead	0.0012 mg/L	EPA 200.8	0.0001 mg/L	9/28/20	IPC	0.015

**Abbreviations/ References:**  
ML = Minimum Level = LRL = RL  
MCL = Maximum Contaminant Level per The EPA  
mg/L = Milligrams Per Liter or PPM  
ug/L = Micrograms Per Liter or PPB  
mpn/100 mls = Most Probable Number Index/ 100 mls  
Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

**Analytical Results**

**TASK NO: 200925074**

**Report To:** Justin Watanabe  
**Company:** Clear Creek School District  
320 Chicago Creek Rd  
Idaho Springs CO 80452

**Bill To:** Justin Watanabe  
**Company:** Clear Creek School District  
320 Chicago Creek Rd  
Idaho Springs CO 80452

<b>Task No.:</b> 200925074	<b>Date Received:</b> 9/25/20
<b>Client PO:</b>	<b>Date Reported:</b> 10/2/20
<b>Client Project:</b> Carlson ES	<b>Matrix:</b> Water - Drinking

**Customer Sample ID** RM 163  
**Sample Date/Time:** 9/22/20 6:34 AM  
**Lab Number:** 200925074-04

Test	Result	Method	ML	Date Analyzed	Analyzed By	MCL
<i>Total</i>						
Lead	0.0015 mg/L	EPA 200.8	0.0001 mg/L	9/28/20	IPC	0.015

**Abbreviations/ References:**  
ML = Minimum Level = LRL = RL  
MCL = Maximum Contaminant Level per The EPA  
mg/L = Milligrams Per Liter or PPM  
ug/L = Micrograms Per Liter or PPB  
mpn/100 mls = Most Probable Number Index/ 100 mls  
Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

**Analytical Results**

**TASK NO: 200925074**

**Report To:** Justin Watanabe  
**Company:** Clear Creek School District  
320 Chicago Creek Rd  
Idaho Springs CO 80452

**Bill To:** Justin Watanabe  
**Company:** Clear Creek School District  
320 Chicago Creek Rd  
Idaho Springs CO 80452

<b>Task No.:</b> 200925074	<b>Date Received:</b> 9/25/20
<b>Client PO:</b>	<b>Date Reported:</b> 10/2/20
<b>Client Project:</b> Carlson ES	<b>Matrix:</b> Water - Drinking

**Customer Sample ID** RM 246  
**Sample Date/Time:** 9/22/20 6:39 AM  
**Lab Number:** 200925074-05

Test	Result	Method	ML	Date Analyzed	Analyzed By	MCL
<i>Total</i>						
Lead	0.0009 mg/L	EPA 200.8	0.0001 mg/L	9/28/20	IPC	0.015

**Abbreviations/ References:**  
ML = Minimum Level = LRL = RL  
MCL = Maximum Contaminant Level per The EPA  
mg/L = Milligrams Per Liter or PPM  
ug/L = Micrograms Per Liter or PPB  
mpn/100 mls = Most Probable Number Index/ 100 mls  
Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

**Analytical Results**

**TASK NO: 200925074**

**Report To:** Justin Watanabe  
**Company:** Clear Creek School District  
320 Chicago Creek Rd  
Idaho Springs CO 80452

**Bill To:** Justin Watanabe  
**Company:** Clear Creek School District  
320 Chicago Creek Rd  
Idaho Springs CO 80452

<b>Task No.:</b> 200925074	<b>Date Received:</b> 9/25/20
<b>Client PO:</b>	<b>Date Reported:</b> 10/2/20
<b>Client Project:</b> Carlson ES	<b>Matrix:</b> Water - Drinking

**Customer Sample ID** RM 242  
**Sample Date/Time:** 9/22/20 6:41 AM  
**Lab Number:** 200925074-06

Test	Result	Method	ML	Date Analyzed	Analyzed By	MCL
<i>Total</i>						
Lead	0.0006 mg/L	EPA 200.8	0.0001 mg/L	9/28/20	IPC	0.015

**Abbreviations/ References:**  
ML = Minimum Level = LRL = RL  
MCL = Maximum Contaminant Level per The EPA  
mg/L = Milligrams Per Liter or PPM  
ug/L = Micrograms Per Liter or PPB  
mpn/100 mls = Most Probable Number Index/ 100 mls  
Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

**Analytical Results**

**TASK NO: 200925074**

**Report To:** Justin Watanabe  
**Company:** Clear Creek School District  
320 Chicago Creek Rd  
Idaho Springs CO 80452

**Bill To:** Justin Watanabe  
**Company:** Clear Creek School District  
320 Chicago Creek Rd  
Idaho Springs CO 80452

<b>Task No.:</b> 200925074	<b>Date Received:</b> 9/25/20
<b>Client PO:</b>	<b>Date Reported:</b> 10/2/20
<b>Client Project:</b> Carlson ES	<b>Matrix:</b> Water - Drinking

**Customer Sample ID** RM 222  
**Sample Date/Time:** 9/22/20 6:44 AM  
**Lab Number:** 200925074-07

Test	Result	Method	ML	Date Analyzed	Analyzed By	MCL
<i>Total</i>						
Lead	0.0010 mg/L	EPA 200.8	0.0001 mg/L	9/28/20	IPC	0.015

**Abbreviations/ References:**  
ML = Minimum Level = LRL = RL  
MCL = Maximum Contaminant Level per The EPA  
mg/L = Milligrams Per Liter or PPM  
ug/L = Micrograms Per Liter or PPB  
mpn/100 mls = Most Probable Number Index/ 100 mls  
Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

**Analytical Results**

**TASK NO: 200925074**

**Report To:** Justin Watanabe  
**Company:** Clear Creek School District  
320 Chicago Creek Rd  
Idaho Springs CO 80452

**Bill To:** Justin Watanabe  
**Company:** Clear Creek School District  
320 Chicago Creek Rd  
Idaho Springs CO 80452

<b>Task No.:</b> 200925074	<b>Date Received:</b> 9/25/20
<b>Client PO:</b>	<b>Date Reported:</b> 10/2/20
<b>Client Project:</b> Carlson ES	<b>Matrix:</b> Water - Drinking

**Customer Sample ID** RM 227  
**Sample Date/Time:** 9/22/20 6:46 AM  
**Lab Number:** 200925074-08

Test	Result	Method	ML	Date Analyzed	Analyzed By	MCL
<i>Total</i>						
Lead	0.0001 mg/L	EPA 200.8	0.0001 mg/L	9/28/20	IPC	0.015

**Abbreviations/ References:**  
ML = Minimum Level = LRL = RL  
MCL = Maximum Contaminant Level per The EPA  
mg/L = Milligrams Per Liter or PPM  
ug/L = Micrograms Per Liter or PPB  
mpn/100 mls = Most Probable Number Index/ 100 mls  
Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY



**Analytical Results**

**TASK NO: 200925074**

**Report To:** Justin Watanabe  
**Company:** Clear Creek School District  
320 Chicago Creek Rd  
Idaho Springs CO 80452

**Bill To:** Justin Watanabe  
**Company:** Clear Creek School District  
320 Chicago Creek Rd  
Idaho Springs CO 80452

<b>Task No.:</b> 200925074	<b>Date Received:</b> 9/25/20
<b>Client PO:</b>	<b>Date Reported:</b> 10/2/20
<b>Client Project:</b> Carlson ES	<b>Matrix:</b> Water - Drinking

**Customer Sample ID** RM 127  
**Sample Date/Time:** 9/22/20 6:51 AM  
**Lab Number:** 200925074-09

Test	Result	Method	ML	Date Analyzed	Analyzed By	MCL
<i>Total</i>						
Lead	0.0007 mg/L	EPA 200.8	0.0001 mg/L	9/28/20	IPC	0.015

**Abbreviations/ References:**

ML = Minimum Level = LRL = RL  
MCL = Maximum Contaminant Level per The EPA  
mg/L = Milligrams Per Liter or PPM  
ug/L = Micrograms Per Liter or PPB  
mpn/100 mls = Most Probable Number Index/ 100 mls  
Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

**Analytical Results**

**TASK NO: 200925074**

**Report To:** Justin Watanabe  
**Company:** Clear Creek School District  
320 Chicago Creek Rd  
Idaho Springs CO 80452

**Bill To:** Justin Watanabe  
**Company:** Clear Creek School District  
320 Chicago Creek Rd  
Idaho Springs CO 80452

<b>Task No.:</b> 200925074	<b>Date Received:</b> 9/25/20
<b>Client PO:</b>	<b>Date Reported:</b> 10/2/20
<b>Client Project:</b> Carlson ES	<b>Matrix:</b> Water - Drinking

**Customer Sample ID** Teachers Workroom  
**Sample Date/Time:** 9/22/20 6:54 AM  
**Lab Number:** 200925074-10

Test	Result	Method	ML	Date Analyzed	Analyzed By	MCL
<i>Total</i>						
Lead	0.0006 mg/L	EPA 200.8	0.0001 mg/L	9/28/20	IPC	0.015

**Abbreviations/ References:**

ML = Minimum Level = LRL = RL  
MCL = Maximum Contaminant Level per The EPA  
mg/L = Milligrams Per Liter or PPM  
ug/L = Micrograms Per Liter or PPB  
mpn/100 mls = Most Probable Number Index/ 100 mls  
Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

# Drinking Water Chain of Custody



<b>Report To Information</b> Company Name: <u>CLEAR CREEK SCHOOL DISTRICT</u> Contact Name: <u>JUSTIN WATANABE</u>	<b>Bill To Information (If different from report to)</b> Company Name: _____ Contact Name: _____	<b>Project Information</b> PWSID: _____ System Name: <u>CARLSEN ES</u> Compliance Samples: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Send Results to CDPHE: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Task Number (Lab Use Only): <b>CAL Task 200925074</b> <p style="text-align: center;">JML</p>
Address: <u>320 CHICAGO CREEK RD</u> City: <u>IDAHO</u> State: <u>CO</u> Zip: <u>80452</u> Phone: <u>720-519-6482</u>	Address: _____ City: _____ State: _____ Zip: _____ Phone: _____	
Email: <u>Justin.Watanabe@csd.org</u>	Email: _____	
Sample Collector: <u>LODY LENTZ</u>	PO Number: _____	
Sample Collector Phone: <u>720-345-7189</u>		

**Commerce City Lab**  
 10411 Heinz Way  
 Commerce City CO 80640

**Lakewood Service Center**  
 12860 W. Cedar Dr, Suite 100A  
 Lakewood CO 80228

Phone: 303-659-2313

[www.coloradolab.com](http://www.coloradolab.com)

PHASE I, II, V Drinking Water Analyses (check requested analysis)														Subcontract Analyses																		
Date	Time	Client Sample ID / Sample Pt ID	No. of Containers	Residual Chlorine (mg/L) P/A Samples Only	Total Coliform P/A	504.1 EDB/DBCP	505 Pests/PCBs	515.4 Herbicides	524.2 VOCs	525.2 SOCs-Pest	531.1 Carbamates	547 Glyphosate	548.1 Endothall	549.2 Diquat	524.2 TTHMs	552.2 HAA5s	Lead/Copper <input checked="" type="checkbox"/>	Nitrate	Nitrite	Fluoride	Inorganics	Alk./Lang. Index (Circle)	TOC, DOC (Circle)	SUVA, UV 254 (Circle)	Gross Alpha/Beta	Radium 226/228	Radon	Uranium	Chlorite			
9/22	6:28 AM	CAFE															X															
9/22	6:30 AM	RM 155															X															
9/22	6:32 AM	RM 159															X															
9/22	6:34 AM	RM 163															X															
9/22	6:39 AM	RM 246															X															
9/22	6:41 AM	RM 242															X															
9/22	6:44 AM	RM 222															X															
9/22	6:46 AM	RM 227															X															
9/22	6:51 AM	RM 127	(10)														X															
9/22	6:54 AM	TEACHER WORKROOM															X															

**Instructions:** Per Quote head only. confirmed w/ Cody - JW  
 C/S Info: \_\_\_\_\_ Seals Present Yes  No  Headspace Yes  No   
 Delivered Via: USPS C/S Charge  Temp. °C/Ice 20.9 Sample Pres. Yes  No

Relinquished By:	Date/Time:	Received By:	Date/Time:	Relinquished By:	Date/Time:	Received By:	Date/Time:
		<u>J. Ku</u>	9/25/20				