

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID Nurse Office
Sample Date/Time: 10/19/21 7:35 AM
Lab Number: 211019005-01

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0060 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID Office Work Room
Sample Date/Time: 10/19/21 7:32 AM
Lab Number: 211019005-02

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0033 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID 157
Sample Date/Time: 10/19/21 7:30 AM
Lab Number: 211019005-03

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0076 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID Kitchen 1
Sample Date/Time: 10/19/21 7:28 AM
Lab Number: 211019005-04

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0119 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID Kitchen 2
Sample Date/Time: 10/19/21 7:28 AM
Lab Number: 211019005-05

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0021 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID 157 Girls
Sample Date/Time: 10/19/21 7:26 AM
Lab Number: 211019005-06

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0070 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

<p>Task No.: 211019005 Client PO: Client Project:</p>	<p>Date Received: 10/19/21 Date Reported: 10/25/21 Matrix: Water - Drinking</p>
--	--

Customer Sample ID 153
Sample Date/Time: 10/19/21 7:20 AM
Lab Number: 211019005-07

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0030 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID Office Bathroom
Sample Date/Time: 10/19/21 7:37 AM
Lab Number: 211019005-08

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0012 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID Costodial Bathroom
Sample Date/Time: 10/19/21 7:36 AM
Lab Number: 211019005-09

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0007 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID Front Bath 2
Sample Date/Time: 10/19/21 7:35 AM
Lab Number: 211019005-10

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0007 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID Front Bathroom 1
Sample Date/Time: 10/19/21 7:36 AM
Lab Number: 211019005-11

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0001 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID Kamatsu Bathroom Adult
Sample Date/Time: 10/19/21 7:50 AM
Lab Number: 211019005-12

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0087 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID Kamatsu 2
Sample Date/Time: 10/19/21 7:50 AM
Lab Number: 211019005-13

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0083 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID Staff Bathroom
Sample Date/Time: 10/19/21 7:41 AM
Lab Number: 211019005-14

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0032 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID Gym Boys
Sample Date/Time: 10/19/21 7:21 AM
Lab Number: 211019005-15

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0069 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID 127 Bathroom
Sample Date/Time: 10/19/21 7:22 AM
Lab Number: 211019005-16

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0098 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID 127
Sample Date/Time: 10/19/21 7:20 AM
Lab Number: 211019005-17

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0053 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005
Client PO:
Client Project:

Date Received: 10/19/21
Date Reported: 10/25/21
Matrix: Water - Drinking

Customer Sample ID 157 Boys
Sample Date/Time: 10/19/21 7:20 AM
Lab Number: 211019005-18

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0010 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID 141
Sample Date/Time: 10/19/21 7:20 AM
Lab Number: 211019005-19

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0061 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID Teacher Lounge
Sample Date/Time: 10/19/21 7:38 AM
Lab Number: 211019005-20

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0092 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID 244 Boys
Sample Date/Time: 10/19/21 7:01 AM
Lab Number: 211019005-21

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0003 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID 248 Girls
Sample Date/Time: 10/19/21 7:01 AM
Lab Number: 211019005-22

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0040 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005
Client PO:
Client Project:

Date Received: 10/19/21
Date Reported: 10/25/21
Matrix: Water - Drinking

Customer Sample ID 155
Sample Date/Time: 10/19/21 7:16 AM
Lab Number: 211019005-23

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0001 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005
Client PO:
Client Project:

Date Received: 10/19/21
Date Reported: 10/25/21
Matrix: Water - Drinking

Customer Sample ID 244 Girls
Sample Date/Time: 10/19/21 7:01 AM
Lab Number: 211019005-24

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0004 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID 250
Sample Date/Time: 10/19/21 7:08 AM
Lab Number: 211019005-25

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0040 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID 159
Sample Date/Time: 10/19/21 7:18 AM
Lab Number: 211019005-26

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0055 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID 153 Girls
Sample Date/Time: 10/19/21 7:20 AM
Lab Number: 211019005-27

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0004 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID 153 Boys
Sample Date/Time: 10/19/21 7:09 AM
Lab Number: 211019005-28

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0002 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID 161 Boys
Sample Date/Time: 10/19/21 7:21 AM
Lab Number: 211019005-29

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0015 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID 248 Boys
Sample Date/Time: 10/19/21 7:17 AM
Lab Number: 211019005-30

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0037 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID 227
Sample Date/Time: 10/19/21 6:50 AM
Lab Number: 211019005-31

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0005 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID Upstairs Girls Bathroom
Sample Date/Time: 10/19/21 6:51 AM
Lab Number: 211019005-32

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0008 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID 240 Girls
Sample Date/Time: 10/19/21 6:40 AM
Lab Number: 211019005-33

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0046 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID Cafeteria 3
Sample Date/Time: 10/19/21 6:40 AM
Lab Number: 211019005-34

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0002 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID Cafeteria 1
Sample Date/Time: 10/19/21 6:34 AM
Lab Number: 211019005-35

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	ND	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID Upstairs Boys
Sample Date/Time: 10/19/21 6:53 AM
Lab Number: 211019005-36

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0002 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID Cafeteria 2
Sample Date/Time: 10/19/21 6:35 AM
Lab Number: 211019005-37

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0005 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID 228
Sample Date/Time: 10/19/21 6:35 AM
Lab Number: 211019005-38

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0054 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID Kamastu Kids Bathroom
Sample Date/Time: 10/19/21 7:48 AM
Lab Number: 211019005-39

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0034 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID 244
Sample Date/Time: 10/19/21 6:58 AM
Lab Number: 211019005-40

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0026 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID 226
Sample Date/Time: 10/19/21 6:44 AM
Lab Number: 211019005-41

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0004 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID 224
Sample Date/Time: 10/19/21 6:48 AM
Lab Number: 211019005-42

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0002 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID Kamatsu
Sample Date/Time: 10/19/21 7:50 AM
Lab Number: 211019005-43

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0053 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID 161 Girls
Sample Date/Time: 10/19/21 7:52 AM
Lab Number: 211019005-44

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0063 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID 163
Sample Date/Time: 10/19/21 7:04 AM
Lab Number: 211019005-45

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0012 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Report To: Justin Watanabe

Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe

Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005
Client PO:
Client Project:

Date Received: 10/19/21
Date Reported: 10/25/21
Matrix: Water - Drinking

Customer Sample ID Gym Girls

Sample Date/Time: 10/19/21 7:06 AM

Lab Number: 211019005-46

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0480 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID 240 Boys
Sample Date/Time: 10/19/21 7:04 AM
Lab Number: 211019005-47

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0014 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID 240
Sample Date/Time: 10/19/21 7:07 AM
Lab Number: 211019005-48

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0027 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID Laundry Room
Sample Date/Time: 10/19/21 6:56 AM
Lab Number: 211019005-49

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0002 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID 225
Sample Date/Time: 10/19/21 6:58 AM
Lab Number: 211019005-50

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0005 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID 222
Sample Date/Time: 10/19/21 6:49 AM
Lab Number: 211019005-51

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0009 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID 246
Sample Date/Time: 10/19/21 6:51 AM
Lab Number: 211019005-52

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0075 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID 242
Sample Date/Time: 10/19/21 6:55 AM
Lab Number: 211019005-53

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0042 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Bill To: Justin Watanabe
Company: Clear Creek School District
320 Chicago Creek Rd
Idaho Springs CO 80452

Task No.: 211019005	Date Received: 10/19/21
Client PO:	Date Reported: 10/25/21
Client Project:	Matrix: Water - Drinking

Customer Sample ID 229
Sample Date/Time: 10/19/21 6:47 AM
Lab Number: 211019005-54

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Lead	0.0015 mg/L	EPA 200.8	0.0001 mg/L	0.015	10/21/21	QC52874	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical QC Summary

TASK NO: 211019005

Report To: Justin Watanabe
Company: Clear Creek School District

Receive Date: 10/19/21
Project Name:

Test	QC Batch ID	QC Type	Result	Method		
Lead	QC52874	Method Blank	ND	EPA 200.8		

Test	QC Batch ID	QC Type	Limits	% Rec	RPD	Method
Lead	QC52874	LCS	90 - 110	95.5	-	EPA 200.8
		MS	70 - 130	84.3	-	
		MSD	0 - 10	-	2.3	

All analyses were performed in accordance with approved methods under the latest revision to 40 CFR Part 136 unless otherwise identified. Based on my inquiry of the person or persons directly responsible for analyzing the wastewater samples and generating the report (s), the analyses, report, and information submitted are, to the best of my knowledge and belief, true, accurate, and complete.



DATA APPROVED FOR RELEASE BY

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
 mg/L = Milligrams Per Liter or PPM
 ug/L = Micrograms Per Liter or PPB
 mpn/100 mls = Most Probable Number Index/ 100 mls
 Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
 (s) Spike amount low relative to the sample amount.
 ND = Not Detected at Reporting Limit.

Drinking Water Chain of Custody

1/6



Commerce City Lab
10411 Heinz Way
Commerce City CO 80640

Lakewood Service Center
12860 W. Cedar Dr, Suite 100A
Lakewood CO 80228

Phone: 303-659-2313

www.coloradolab.com

Report To Information		Bill To Information (If different from report to)		Project Information	
Company Name: <u>CLEAR CREEK SCHOOL DISTRICT</u>		Company Name: _____		PWSID: _____	
Contact Name: <u>JUSTIN WATANABE</u>		Contact Name: _____		System Name: _____	
Address: <u>320 CO-103</u>		Address: _____		Compliance Samples: Yes <input type="checkbox"/> No <input type="checkbox"/>	
City: <u>DONALD SPRINGS</u> State: <u>CO</u> Zip: <u>80452</u>		City: _____ State: _____ Zip: _____		Send Results to CDPHE: Yes <input type="checkbox"/> No <input type="checkbox"/>	
Phone: <u>720 519-6482</u>		Phone: _____		Task Number (Lab Use Only) CAL Task 211019005 NAB	
Email: <u>JUSTIN.WATANABE@CLEARCREEKSDISTRICT.CO</u>		Email: <u>CCSDRE1.ORG</u>			
Sample Collector: _____		PO Number: _____			
Sample Collector Phone: _____		PO Number: _____			

PHASE I, II, V Drinking Water Analyses (check requested analysis) **Subcontract Analyses**

Date	Time	Client Sample ID / Sample Pt ID	No. of Containers	Residual Chlorine (mg/L) P/A Samples Only	Total Coliform P/A	504.1 EDB/DBCP	505 Pests/PCBs	515.4 Herbicides	524.2 VOCs	525.2 SOCs-Pest	531.1 Carbamates	547 Glyphosate	548.1 Endothal	549.2 Diquat	524.2 TTHMs	552.2 HAA5s	Lead/Copper	Nitrate	Nitrite	Fluoride	Inorganics	Alk./Lang. Index (Circle)	TOC, DOC (Circle)	SUVA, UV 254 (Circle)	Gross Alpha/Beta	Radium 226/228	Radon	Uranium	Chlorite
10/19/20	7:35am	nurse office																											
10/19/20	7:32am	office work room																											
10/19/20	7:30am	157																											
10/19/20	7:28am	Kitchen 1																											
10/19/20	7:28am	Kitchen 2																											
10/19/20	7:26am	157 girls																											
10/19/20	7:26am	153																											
10/19/20	7:37am	Office Bathroom																											
10/19/20	7:36am	custodial Bathroom																											
10/19/20	7:35am	front Bath 2																											

Instructions:				C/S Info:				Seals Present Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Headspace Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>			
Delivered Via: <u>Hand</u>				C/S Charge <input type="checkbox"/>				Temp. °C/Ice <u>20.8 N</u> Sample Pres. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>			

Relinquished By: _____	Date/Time: _____	Received By: <u>A. FOR</u>	Date/Time: <u>10/19/2024</u>	Relinquished By: <u>Dakota Smith</u>	Date/Time: _____	Received By: _____	Date/Time: _____
------------------------	------------------	----------------------------	------------------------------	--------------------------------------	------------------	--------------------	------------------

Drinking Water Chain of Custody

216



Commerce City Lab
10411 Heinz Way
Commerce City CO 80640

Lakewood Service Center
12860 W. Cedar Dr, Suite 100A
Lakewood CO 80228

Phone: 303-659-2313

www.coloradolab.com

Report To Information	Bill To Information (If different from report to)	Project Information
Company Name: <u>CCSD PG. 2</u>	Company Name: _____	PWSID: _____
Contact Name: _____	Contact Name: _____	System Name: _____
Address: _____	Address: _____	Compliance Samples: Yes <input type="checkbox"/> No <input type="checkbox"/>
City: _____ State: _____ Zip: _____	City: _____ State: _____ Zip: _____	Send Results to CDPHE: Yes <input type="checkbox"/> No <input type="checkbox"/>
Phone: _____	Phone: _____	Task Number (Lab Use Only) CAL Task 211019005 NAB
Email: _____	Email: _____	
Sample Collector: _____	PO Number: _____	
Sample Collector Phone: _____		

			PHASE I, II, V Drinking Water Analyses (check requested analysis)																Subcontract Analyses											
Date	Time	Client Sample ID / Sample Pt ID	No. of Containers	Residual Chlorine (mg/L) P/A Samples Only	Total Coliform P/A	504.1 EDB/DBCP	505 Pests/PCBs	515.4 Herbicides	524.2 VOCs	525.2 SOCs-Pest	531.1 Carbamates	547 Glyphosate	548.1 Endothal	549.2 Diquat	524.2 TTHMs	552.2 HAA5s	Lead/Copper	Nitrate	Nitrite	Fluoride	Inorganics	Alk./Lang. Index (Circle)	TOC, DOC (Circle)	SUVA, UV 254 (Circle)	Gross Alpha/Beta	Radium 226/228	Radon	Uranium	Chlorite	
10/19/20	7:36 am	Front Bathroom 1																												
10/19/20	7:50 am	KAMATSU Bathroom adult																												
10/19/20	7:50 am	Kamatsu 2																												
10/19/20	7:48 am	Staff Bathroom																												
10/19/20	7:21 am	GYM BOYS																												
10/19/20	7:22 am	127 Bathroom																												
10/19/20	7:20 am	127																												
10/19/20	7:20 am	157 BOYS																												
10/19/20	7:20 am	141																												
10/19/20	7:38 am	teacher lounge																												
Instructions:										C/S Info:								Seals Present Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Headspace Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>												
										Delivered Via: <u>Hand</u>								C/S Charge <input type="checkbox"/> Temp. <u>20.8</u> °C / Ice <u>N</u> Sample Pres. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>												
Relinquished By:			Date/Time:			Received By: <u>A. Ford</u>			Date/Time: <u>10/19/21</u>			Relinquished By: <u>Dorothy Stutz</u>			Date/Time:			Received By:			Date/Time:									

Drinking Water Chain of Custody

316



Commerce City Lab
10411 Heinz Way
Commerce City CO 80640

Lakewood Service Center
12860 W. Cedar Dr, Suite 100A
Lakewood CO 80228

Phone: 303-659-2313

www.coloradolab.com

Report To Information		Bill To Information (If different from report to)		Project Information	
Company Name: <u>CCSD PG.3</u>		Company Name: _____		PWSID: _____	
Contact Name: _____		Contact Name: _____		System Name: _____	
Address: _____		Address: _____		Compliance Samples: Yes <input type="checkbox"/> No <input type="checkbox"/>	
City: _____	State: _____	Zip: _____	City: _____	State: _____	Zip: _____
Phone: _____		Phone: _____		Task Number (Lab Use Onl): CAL Task	
Email: _____		Email: _____		211019005	
Sample Collector: _____		Sample Collector: _____		NAB	
Sample Collector Phone: _____		PO Number: _____			

			PHASE I, II, V Drinking Water Analyses (check requested analysis)																Subcontract Analyses											
Date	Time	Client Sample ID / Sample Pt ID	No. of Containers	Residual Chlorine (mg/L) P/A Samples Only	Total Coliform P/A	504.1 EDB/DBCP	505 Pests/PCBs	515.4 Herbicides	524.2 VOCs	525.2 SOCs-Pest	531.1 Carbamates	547 Glyphosate	548.1 Endothal	549.2 Diquat	524.2 TTHMs	552.2 HAA5s	Lead/Copper	Nitrate	Nitrite	Fluoride	Inorganics	Alk./Lang. Index (Circle)	TOC, DOC (Circle)	SUVA, UV 254 (Circle)	Gross Alpha/Beta	Radium 226/228	Radon	Uranium	Chlorite	
10/19/21	7:01am	244 BOYS																												
10/19/21	7:01am	248 girls																												
10/19/21	7:16am	155																												
10/19/21	7:01am	244 girls																												
10/19/21	7:08am	250																												
10/19/21	7:14am	159																												
10/19/21	7:20am	153 girls																												
10/19/21	7:09am	153 BOYS																												
10/19/21	7:21am	161 BOYS																												
10/19/21	7:17am	248 BOYS																												
Instructions:										C/S Info:								Seals Present Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Headspace Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>												
										Delivered Via: <u>Hand</u>								C/S Charge <input type="checkbox"/> Temp. <u>20.8</u> °C/Ice <u>N</u> Sample Pres. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>												
Relinquished By:			Date/Time:			Received By: <u>A. FOR</u>			Date/Time: <u>10/19/21</u>			Relinquished By: <u>Dakota Setz</u>			Date/Time:			Received By:			Date/Time:									

Drinking Water Chain of Custody

416



Commerce City Lab
10411 Heinz Way
Commerce City CO 80640

Lakewood Service Center
12860 W. Cedar Dr, Suite 100A
Lakewood CO 80228

Phone: 303-659-2313

www.coloradolab.com

Report To Information	Bill To Information (If different from report to)	Project Information
Company Name: <u>CCSID PG 6</u>	Company Name: _____	PWSID: _____
Contact Name: _____	Contact Name: _____	System Name: _____
Address: _____	Address: _____	Compliance Samples: Yes <input type="checkbox"/> No <input type="checkbox"/>
City: _____ State: _____ Zip: _____	City: _____ State: _____ Zip: _____	Send Results to CDPHE: Yes <input type="checkbox"/> No <input type="checkbox"/>
Phone: _____	Phone: _____	Task Number (Lab Use Only) CAL Task 211019005
Email: _____	Email: _____	NAB
Sample Collector: _____	PO Number: _____	
Sample Collector Phone: _____		

			PHASE I, II, V Drinking Water Analyses (check requested analysis)																	Subcontract Analyses										
Date	Time	Client Sample ID / Sample Pt ID	No. of Containers	Residual Chlorine (mg/L) P/A Samples Only	Total Coliform P/A	504.1 EDB/DBCP	505 Pests/PCBs	515.4 Herbicides	524.2 VOCs	525.2 SOCs-Pest	531.1 Carbamates	547 Glyphosate	548.1 Endothall	549.2 Diquat	524.2 TTHMs	552.2 HAA5s	<u>Lead</u> Copper	Nitrate	Nitrite	Fluoride	Inorganics	Alk./Lang. Index (Circle)	TOC, DOC (Circle)	SUVA, UV 254 (Circle)	Gross Alpha/Beta	Radium 226/228	Radon	Uranium	Chlorite	
10/19/21	6:50am	227																												
10/19/21	6:51 am	UPstairs girls Bedroom																												
10/19/21	6:40 am	240 girls																												
10/19/21	6:40 am	cafeteria 3																												
10/19/21	6:34 am	cafeteria 1																												
10/19/21	6:53 am	UPstairs BOYS																												
10/19/21	6:35 am	cafeteria 2																												
10/19/21	6:35 am	228																												
10/19/21	7:48am	Kamatsu kids Bathroom																												
10/19/21	6:58am	244 244																												
Instructions:										C/S Info:								Seals Present Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Headspace Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>												
										Delivered Via: <u>Hand</u> C/S Charge <input type="checkbox"/>								Temp. <u>20.8</u> °C/Ice <u>N</u> Sample Pres. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>												
Relinquished By:			Date/Time:			Received By:			Date/Time:			Relinquished By:			Date/Time:			Received By:			Date/Time:									
						<u>A. Fork</u>			<u>10/19/21</u>			<u>Dakota Shtz</u>																		

Report To Information			Bill To Information (If different from report to)			Project Information		
Company Name: <u>CCSD PG. 4</u>			Company Name: _____			PWSID: _____		
Contact Name: _____			Contact Name: _____			System Name: _____		
Address: _____			Address: _____			Compliance Samples: Yes <input type="checkbox"/> No <input type="checkbox"/>		
City: _____	State: _____	Zip: _____	City: _____	State: _____	Zip: _____	Send Results to CDPHE: Yes <input type="checkbox"/> No <input type="checkbox"/>		
Phone: _____			Phone: _____			Task Number (Lab Use Only) CAL Task		
Email: _____			Email: _____			211019005		
Sample Collector: _____			PO Number: _____			NAB		
Sample Collector Phone: _____								

Commerce City Lab
10411 Heinz Way
Commerce City CO 80640

Lakewood Service Center
12860 W. Cedar Dr, Suite 100A
Lakewood CO 80228

Phone: 303-659-2313

www.coloradolab.com

			PHASE I, II, V Drinking Water Analyses (check requested analysis)																	Subcontract Analyses										
Date	Time	Client Sample ID / Sample Pt ID	No. of Containers	Residual Chlorine (mg/L) P/A Samples Only	Total Coliform P/A	504.1 EDB/DBCP	505 Pests/PCBs	515.4 Herbicides	524.2 VOCs	525.2 SOCs-Pest	531.1 Carbamates	547 Glyphosate	548.1 Endothal	549.2 Diquat	524.2 TTHMs	552.2 HAA5s	Lead/Copper	Nitrate	Nitrite	Fluoride	Inorganics	Alk./Lang. Index (Circle)	TOC, DOC (Circle)	SUVA, UV 254 (Circle)	Gross Alpha/Beta	Radium 226/228	Radon	Uranium	Chlorite	
10/19/21	6:44am	226																												
10/19/21	6:48am	224																												
10/19/21	7:50am	Kamarsu																												
10/19/21	7:52am	161 girls																												
10/19/21	7:06am	163																												
10/19/21	7:06am	94m girls																												
10/19/21	7:07am	240 BOYS																												
10/19/21	7:07am	240																												
10/19/21	6:56am	Handvrt Room																												
10/19/21	6:58am	225																												

Instructions:

C/S Info: _____

Delivered Via: Hand C/S Charge Temp. °C / Ice N

Seals Present Yes No Headspace Yes No

Sample Pres. Yes No

Relinquished By: _____	Date/Time: _____	Received By: <u>A. Fork</u>	Date/Time: <u>10/19/21 9:24</u>	Relinquished By: <u>Dakota Shtz</u>	Date/Time: _____	Received By: _____	Date/Time: _____
------------------------	------------------	-----------------------------	---------------------------------	-------------------------------------	------------------	--------------------	------------------

Drinking Water Chain of Custody

616



Report To Information			Bill To Information (If different from report to)			Project Information		
Company Name: <u>CCSD PG. 5</u>			Company Name: _____			PWSID: _____		
Contact Name: _____			Contact Name: _____			System Name: _____		
Address: _____			Address: _____			Compliance Samples: Yes <input type="checkbox"/> No <input type="checkbox"/>		
City: _____	State: _____	Zip: _____	City: _____	State: _____	Zip: _____	Send Results to CDPHE: Yes <input type="checkbox"/> No <input type="checkbox"/>		
Phone: _____			Phone: _____			Task Number (Lab Use Only) CAL Task 211019005 NAB		
Email: _____			Email: _____					
Sample Collector: _____			PO Number: _____					
Sample Collector Phone: _____								

Commerce City Lab
10411 Heinz Way
Commerce City CO 80640

Lakewood Service Center
12860 W. Cedar Dr, Suite 100A
Lakewood CO 80228

Phone: 303-659-2313

www.coloradolab.com

			PHASE I, II, V Drinking Water Analyses (check requested analysis)																	Subcontract Analyses											
Date	Time	Client Sample ID / Sample Pt ID	No. of Containers	Residual Chlorine (mg/L) P/A Samples Only	Total Coliform P/A	504.1 EDB/DBCP	505 Pests/PCBs	515.4 Herbicides	524.2 VOCs	525.2 SOCs-Pest	531.1 Carbamates	547 Glyphosate	548.1 Endothal	549.2 Diquat	524.2 TTHMs	552.2 HAA5s	<u>Cadmium</u>	Nitrate	Nitrite	Fluoride	Inorganics	Alk./Lang. Index (Circle)	TOC, DOC (Circle)	SUVA, UV 254 (Circle)	Gross Alpha/Beta	Radium 226/228	Radon	Uranium	Chlorite		
10/14/21	6:49am	222																													
10/19/21	6:51am	246																													
10/19/21	6:55am	242																													
10/19/21	6:47am	229																													
Instructions:										C/S Info:										Seals Present Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Headspace Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>											
Relinquished By:										Date/Time:										Received By:						Date/Time:					
																				Delivered Via: <u>Hand</u> C/S Charge <input type="checkbox"/> Temp. °C/Ice <u>N</u> Sample Pres. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>											
A. Ford										10/19/21 9:24										Deborah Stutz											